

ARCHITECHNICS, INC.
510 MAINE STREET
QUINCY, ILLINOIS 62301

PROJECT NO. : 5661B

ADDENDUM NO.: 2

ISSUED: 12/8/2017

Project: MECHANICAL SYSTEM REPLACEMENT
BROWN COUNTY COURTHOUSE
200 EAST COURT STREET
MOUNT STERLING, ILLINOIS 62353

This addendum becomes a part of the bidding and contract documents and modifies the drawings and specifications dated November 17, 2017. Acknowledge receipt of this addendum by noting such on the Contractor's Proposal (Bid) Form.

FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION

ITEM	DESCRIPTION
<u>DRAWINGS:</u>	
1.0 SPECS 7433 NEUTRAL AIR UNIT	Add: Aeon and Mitsubishi PremiSys are approved. Unit shall have two digital or variable speed compressors. All points listed in specs 23 8200 shall be shown in control system.
2.0 MECHANICAL DRAWINGS	Add: Any new condensate piping shall be insulated with 1/2" Armaflex or equal pipe insulation.

This addendum consists of 1 page. Attachments: