

ARCHITECHNICS, INC.  
510 MAINE STREET  
QUINCY, ILLINOIS 62301

PROJECT NO. 5899

ADDENDUM NO. 2

ISSUED: April 20, 2020

PROJECT: TITLE III GRANT – BUILDING "A"  
SCIENCE LABORATORY RENOVATIONS  
QUINCY UNIVERSITY – NORTH CAMPUS  
1901 NORTH 18<sup>th</sup> STREET – QUINCY, ADAMS COUNTY, ILLINOIS  
ARCHITECHNICS, INC. PROJECT NO. 5899

This addendum becomes a part of the bidding and contract documents and modifies the drawings, project manual and specifications, dated January 31, 2020. Acknowledge receipt of this addendum by noting such on the Contractor's Proposal (Bid) Form.

FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION

<u>ITEM</u>	<u>LOCATION</u>	<u>DESCRIPTION</u>
-------------	-----------------	--------------------

**GENERAL**

1.0 Email Bids Accepted Add:

**Email bids will be accepted. Email your entire bid to [imiller@architechnicsinc.com](mailto:imiller@architechnicsinc.com) Combine all bid documents, bid bond, and other files into (1) pdf attachment to your bid email. PLEASE PUT A BASIC COVER/TITLE PAGE ON YOUR EMAIL ATTACHMENT PDF SO YOUR BID FORM IS NOT THE FIRST PAGE. We will print the attachment and put it in a sealed envelope to be opened at the bid opening.**

2.0 ONLINE BID OPENING

**Due to the social distancing guidelines issued by the state and federal government the public bid opening will not be available to attend in person.**

**Please email or drop your bid off ahead of time and you can view the bid opening online.**

**Here is the link to view the online bid opening.**

**<https://meet.google.com/rqa-vwdg-sye>**

3.0	Clarify:	A hard copy of plans and specifications is not required to submit a bid.
-----	----------	--

4.0	Clarify:	The owner will install all IT cabling. The contractor is responsible for installing infrastructure, conduit, etc required for IT cabling runs.
-----	----------	--

**DRAWINGS:**

1.0 Dwg. No. A5	Add/Clarify:	Equipment Schedule, Item #5E, Vent Hood shall be Labconco or equal 3955200. Include stand and work surface per schedule.
-----------------	--------------	--

End of Addendum No. 2