

ADAMS COUNTY COURTHOUSE

ILLINOIS

521 VERMONT STREET QUINCY, ADAMS COUNTY, ILLINOIS





AREA LOCATION PLAN

GENERAL NOTES

- 1. CONTRACTOR TO VERIFY ALL DIMENSIONS
- 2. ANY DISCREPANCIES BETWEEN STATED AND EXISTING CONDITIONS SHALL BE REPORTED IMMEDIATELY TO THE
- 3. DISCREPANCIES OR CONFLICTS BETWEEN SPECIFICATIONS AND DRAWINGS SHALL BE MADE KNOWN TO THE ARCHITECT FOR
- 4. THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROTECTING THOSE AREAS TO REMAIN UNDISTURBED DURING CONSTRUCTION.
- THE CONSTRUCTION SITE, AND HE IS SOLELY RESPONSIBLE FOR SAFETY MEASURES. THE CONTRACTOR IS ALSO SOLELY RESPONSIBLE FOR CONSTRUCTION MEANS, METHODS, AND
- 6. THE CONTRACTOR SHALL CONFORM TO ALL LOCAL AND STATE CODES AND RECEIVE LOCAL AND STATE APPROVAL WHERE NECESSARY PRIOR TO CONSTRUCTION.
- 7. THE CONTRACTOR SHALL GIVE ALL NECESSARY NOTICES AND OBTAIN ALL PERMITS AND PAY ALL LEGAL FEES. HE SHALL ALSO COMPLY WITH ALL CITY, COUNTY, AND STATE BUILDING LAWS,
- OR LOSS OF ANY REFERENCE POINTS, MONUMENTS, HUBS AND STAKED LOT CORNERS DURING THE CONSTRUCTION OF HIS WORK, AND SHALL BEAR THE COST OF REPLACING SAME.
- 9. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ANY DAMAGE DONE TO THE PREMISES OR ADJACENT PREMISES. OR INJURIES TO THE PUBLIC DURING THE CONSTRUCTION OF THE WORK. CAUSED BY HIMSELF, HIS SUBCONTRACTOR, OR THE CARELESSNESS OF ANY OF HIS EMPLOYEES.
- 10. THE CONTRACTOR MUST UNDERSTAND THAT THE WORK IS ENTIRELY AT HIS RISK UNTIL SAME IS ACCEPTED, AND HE WILL BE HELD RESPONSIBLE FOR ITS SAFETY.
- 11. THE CONTRACTOR SHALL FURNISH AND INSTALL ALL NECESSARY TEMPORARY WORKS FOR THE PROTECTION OF THE WORK, INCLUDING BARRICADES, WARNING SIGNS, LIGHTS, ETC.
- 12. SITE LAYOUT IS TO BE AS PER ARCHITECTURAL DRAWINGS AND SPECIFICATIONS PREPARED BY ARCHITECT.
- 13. THE CONTRACTOR SHALL PROVIDE THE ARCHITECT WITH ONE SET OF PRINTS MARKED WITH ANY CHANGES FROM ORIGINAL CONTRACT DOCUMENTS.
- 14. ALL EXISTING CIRCUIT CONDUCTORS AND RACEWAYS IN BUILDING UNITS TO REMAIN UNLESS NOTED OTHERWISE.

A.D.A. COMPLIANCE

THIS PROJECT SHALL BE IN COMPLIANCE WITH GUIDELINES OF THE AMERICANS WITH DISABILITIES ACT (A.D.A.)

AMERICANS WITH DISABILITIES ACT (A.D.A.)

ARCHITECHNICS, TO THE BEST OF ITS ABILITY, HAS EXERCISED PROFESSIONAL EFFORTS TO INTERPRET THE INTENT OF THE "AMERICANS WITH DISABILITIES ACT", AND OTHER APPLICABLE FEDERAL, STATE AND LOCAL CODES AND REQUIREMENTS. ARCHITECHNICS CANNOT GUARANTEE TOTAL COMPLIANCE WITH ANY WORK DIRECTLY RELATED TO THE A.D.A., WHEN THE OWNER PERFORMS AND/OR AUTHORIZES WORK USING THESE DOCUMENTS AND/OR DRAWINGS.

INDEX OF DRAWINGS

COVER SHEET

FLOOR PLANS AND SECTIONS MACHINE ROOM FLOOR PLAN

CURRENT DATE: 10/5/2020



LICENSE EXPIRES: 11/30/22

SECTION

SOLID CORE

STANDARD

STORAGE

PANELS

TACK BOARD TAPE AND SAND TELECOMMUNICATIONS DEVICE FOR DEAF

TERRAZZO

TERRAZZO TILE THICK/THICKNESS

THRESHOLD

TOILET PAPER

TRANSITION

TYPICAL

TOP AND BOTTOM

UNDERWRITERS

LABORATORIES

UNLESS NOTED

OTHERWISE

VERTICAL VESTIBULE

VINYL WALL COVERING

WINDOW

WITH OUT

WOOD

TREADS

TYPICAL

UNDERWRITERS

WIRE GLASS

UTILITY POLE

VAPOR BARRIER

VINYL COMPOSITION

VITRIFIED CLAY PIPE

WELDED WIRE FABRIC

WATER CLOSET

TEMPERED GLASS

TEMPERED REFLECTIVE

TONGUE AND GROOVE

SPECIFICATION

STORM SEWER

STRUCTURAL GLAZED

SUSPENDED ACOUSTICAL

STAIN AND VARNISH

STAINLESS STEEL

SHEET

SHT.

S.& V.

S.S.

STD.

STL.

STOR.

ST.S.

S.G.T.

T.R.G.

T.T.

T'HOLD

T. & G.

T. & B.

TYP.

U.L.

U.N.O.

VERT.

V.C.T.

W.C.

W.G.

W/O

WD.

TYP.

W.W.F.

U.P.

TRANS.

ROUGH OPENING

SANITARY (SEWER)

RUBBER TILE

RUBBER STAIR TREAD

ISSUED FOR BIDDING

SSUE DATE: **10/5/2020** REVISIONS

> COVER SHEET

PROJECT NUMBER: 5991


DWG. NO.


ABBREVIATIONS


					MAKEUR AIR UNIT
BV	ABOVE	DWG	DRAWING	M.A.U.	MAKEUP AIR UNIT
.F.F.	ABOVE FINISHED FLOOR	D.F.	DRINKING FOUNTAIN	M.H.	MANHOLE
DD'N.	ADDITION	EA.	EACH	MFGR.	MANUFACTURER
.C.	AIR CONDITIONING	E.W.	EACH WAY	M.T.	MARBLE TILE
.H.U.	AIR HANDLING UNIT	E.M.R.	ELASTOMERIC MEMBRANE	MK.	MARK
LT	ALTERNATE		ROOFING	M.O.	MASONRY OPENING
LUM	ALUMINUM	ELEC.	ELECTRIC	MATL.	MATERIAL
.D.A.	AMERICANS WITH	E.P.	ELECTRIC PANELBOARD	MECH.	MECHANICAL
	DISABILITIES ACT	EL	ELEVATION	MET.	METAL
NCS.	ANCHORS	ELEV.	ELEVATOR	MIN.	MINIMUM
UTO.	AUTOMATIC	EXH.	EXHAUST	MISC.	MISCELLANEOUS
M.	BEAM	E.F.	EXHAUST FAN	M.R.	MOISTURE RESISTANT
R'G.	BEARING	EXIST	EXISTING	MTD.	MOUNTED
ITUM.	BITUMINOUS	E. J.	EXPANSION JOINT	N.D.	NAPKIN DISPENSER
LK'G.	BLOCKING	EXT	EXTERIOR	N.I.C.	NOT IN CONTRACT
LDG	BUILDING	E.I.F.S.	EXTERIOR INSULATION	NOM.	NOMINAL
D.	BOARD		FINISH SYSTEM	NO.	NUMBER
TM.	BOTTOM	F.W.C.	FABRIC WALL COVERING	OFC.	OFFICE
.P.	BRICK PAVERS	F.V.	FIELD VERIFY	O.C.	ON CENTER
LDG.	BUILDING	FIN.	FINISH	OPG.	OPENING
UR	BUILT-UP ROOF	F.E.C.	FIRE EXTINGUISHER	OPP. HND.	OPPOSITE HAND
A.	CARPET		CABINET	OH.	OVERHEAD
.l.	CAST IRON	FIX.	FIXTURE	PT.	PAINT
AT	CATALOG	FL.	FLOOR	PR.	PAIR
LG.	CEILING	F.D.	FLOOR DRAIN	PARTN.	PARTITION
T.	CERAMIC TILE	FLOUR.	FLUORESCENT	PERF.	PERFORATED
.W.B.	CERAMIC WALL BASE	FTG.	FOOTING	P.D.	PRESSURE DROP
.w.b.	CHALK BOARD	FND.	FOUNDATION	PLAS.	PLASTIC
LOS	CLOSET	G.P.M.	GALLONS PER MINUTE	P.S.	PLUMBING STACK
.0.	CLEAN OUT	GALV	GALVANIZED	P.V.	PLUMBING VENT
0.	COMPANY	GA.	GAUGE	PLYWD.	PLYWOOD
OMP	COMPOSITION	G.W.T.	GLAZED WALL TILE	P.V.C.	POLYVINYL CHLORIDE
ONC	CONCRETE	G.B.	GRAB BAR	P.S.F.	POUNDS PER SQUARE
.M.U.	CONCRETE MASONRY	G.F.B.	GROUND FACE BRICK		FOOT
.IVI.O.	UNIT	GYP. BD.	GYPSUM WALLBOARD	PREFIN.	PREFINISHED
OND	CONDENSATION	H.D.	HAIR/HAND DRYER		PROJECT MANUAL
ONN.	CONNECTION	HC	HANDICAPPED	QTY.	QUANTITY
ONST.	CONSTRUCTION	HR.	HANDRAIL	Q.T.	QUARRY TILE
.J.	CONSTRUCTION JOINT	HDWE.	HARDWARE	RAD.	RADIUS
ONT	CONTINUOUS	H.V.A.C.	HEATING, VENTILATING,	RECEP.	RECEPTACLE
ONTR.	CONTRACTOR		& AIR CONDITIONING	REF.	REFERENCE
OR'D	CORRUGATED	HT.	HEIGHT	R.A.	RETURN AIR
ORR.	CORRIDOR	H.C.	HOLLOW CORE	R.H.	RIGHT HAND
NTR.	COUNTER	H.M.	HOLLOW METAL	R.	RISERS
		HORIZ.	HORIZONTAL	R.D.	ROOF DRAIN
.R.	CRUSHED ROCK	INC.	INCORPORATED	R.B.	RUBBER BASE
.F.M.	CUBIC FEET PER MINUTE	INSUL.	INSULATION	R.C.B.	RUBBER COVE BASE
EMO	DEMOLITION	INSUL.G.	INSULATED GLASS	REQD.	REQUIRED
EMO	DETAIL	JAN.	JANITOR	R.O.W.	RIGHT OF WAY
⊏1	DETAIL	IT.	IOINT	11.0.00	MOITI OF WAT

H.U.	AIR HANDLING UNIT ALTERNATE	E.M.R.	ELASTOMERIC MEMBRANE ROOFING
_T		ELEC.	ELECTRIC
_UM	ALUMINUM	E.P.	ELECTRIC PANELBOARD
D.A.	AMERICANS WITH	E.F.	ELECTRIC PANELBOARD ELEVATION
	DISABILITIES ACT		ELEVATION
NCS.	ANCHORS	ELEV.	
JTO.	AUTOMATIC	EXH.	EXHAUST
Л.	BEAM	E.F.	EXHAUST FAN
R'G.	BEARING	EXIST	EXISTING
TUM.	BITUMINOUS	E. J.	EXPANSION JOINT
.K'G.	BLOCKING	EXT	EXTERIOR
.DG	BUILDING	E.I.F.S.	EXTERIOR INSULATION
).	BOARD		FINISH SYSTEM
ΓМ.	воттом	F.W.C.	FABRIC WALL COVERING
Р.	BRICK PAVERS	F.V.	FIELD VERIFY
DG.	BUILDING	FIN.	FINISH
JR	BUILT-UP ROOF	F.E.C.	FIRE EXTINGUISHER
٨.	CARPET		CABINET
l.	CAST IRON	FIX.	FIXTURE
ΑT	CATALOG	FL.	FLOOR
 .G.	CEILING	F.D.	FLOOR DRAIN
T.	CERAMIC TILE	FLOUR.	FLUORESCENT
w.B.	CERAMIC WALL BASE	FTG.	FOOTING
В.	CHALK BOARD	FND.	FOUNDATION
.os.	CLOSET	G.P.M.	GALLONS PER MINUTE
0	CLEAN OUT	GALV	GALVANIZED
O. O.	COMPANY	GA.	GAUGE
OMP.	COMPOSITION	G.W.T.	GLAZED WALL TILE
ONC	CONCRETE	G.B.	GRAB BAR
M.U.	CONCRETE MASONRY	G.F.B.	GROUND FACE BRICK
IVI.O.	UNIT	GYP. BD.	GYPSUM WALLBOARD
OND	CONDENSATION	H.D.	HAIR/HAND DRYER
ONN.	CONNECTION	HC	HANDICAPPED
ONST.	CONSTRUCTION	HR.	HANDRAIL
J.	CONSTRUCTION JOINT	HDWE.	HARDWARE
o. DNT	CONTINUOUS	H.V.A.C.	HEATING, VENTILATING,
ONTR.	CONTRACTOR		& AIR CONDITIONING
DR'D	CORRUGATED	HT.	HEIGHT
ORR.	CORRIDOR	H.C.	HOLLOW CORE
NTR.	COUNTER	H.M.	HOLLOW METAL
		HORIZ.	HORIZONTAL
R.	CRUSHED ROCK CUBIC FEET PER	INC.	INCORPORATED
F.M.		INSUL.	INSULATION
-140	MINUTE	INSUL.G.	INSULATED GLASS
EMO	DEMOLITION	JAN.	JANITOR
ĒΤ	DETAIL	JT.	JOINT
A	DIAMETER	J.F.	JOINT FILLER
M.	DIMENSION	JST.	JOIST
SP.	DISPENSER	J.B.	JUNCTION BOX
V.	DIVISION	LAM.	LAMINATE
₹.	DOOR		
BL.	DOUBLE	LAV.	LAVATORY
S.	DOWNSPOUT	L.H.	LEFT HAND
		LG.	LONG

U.	AIR HANDLING UNIT	E.M.R.	ELASTOMERIC MEMBRANE	MK.	MARK
	ALTERNATE		ROOFING	M.O.	MASONRY OF
M	ALUMINUM	ELEC.	ELECTRIC	MATL.	MATERIAL
Α.	AMERICANS WITH	E.P.	ELECTRIC PANELBOARD	MECH.	MECHANICAL
	DISABILITIES ACT	EL	ELEVATION	MET.	METAL
S.	ANCHORS	ELEV.	ELEVATOR	MIN.	MINIMUM
o.	AUTOMATIC	EXH.	EXHAUST	MISC.	MISCELLANE
O.	BEAM	E.F.	EXHAUST FAN	M.R.	MOISTURE RE
		EXIST	EXISTING	MTD.	MOUNTED
). 	BEARING	E. J.	EXPANSION JOINT	N.D.	NAPKIN DISPE
JM.	BITUMINOUS	EXT	EXTERIOR	N.I.C.	NOT IN CONT
G.	BLOCKING	E.I.F.S.	EXTERIOR INSULATION	NOM.	NOMINAL
G	BUILDING		FINISH SYSTEM	NO.	NUMBER
	BOARD	F.W.C.	FABRIC WALL COVERING	OFC.	OFFICE
•	BOTTOM	F.V.	FIELD VERIFY	o.c.	ON CENTER
_	BRICK PAVERS	FIN.	FINISH	OPG.	OPENING
G.	BUILDING	F.E.C.	FIRE EXTINGUISHER		OPPOSITE HA
	BUILT-UP ROOF	1.2.0.	CABINET	OH.	OVERHEAD
	CARPET	FIX.	FIXTURE	PT.	PAINT
	CAST IRON	FL.	FLOOR	PR.	
	CATALOG	F.D.	FLOOR DRAIN		PAIR
	CEILING	FLOUR.	FLUORESCENT	PARTN.	PARTITION
	CERAMIC TILE	FTG.	FOOTING	PERF.	PERFORATED
В.	CERAMIC WALL BASE	FND.		P.D.	PRESSURE D
	CHALK BOARD	G.P.M.	FOUNDATION	PLAS.	PLASTIC
S.	CLOSET		GALLONS PER MINUTE	P.S.	PLUMBING ST
	CLEAN OUT	GALV	GALVANIZED	P.V.	PLUMBING VE
	COMPANY	GA.	GAUGE	PLYWD.	PLYWOOD
1P.	COMPOSITION	G.W.T.	GLAZED WALL TILE	P.V.C.	POLYVINYL C
IC	CONCRETE	G.B.	GRAB BAR	P.S.F.	POUNDS PER
U.	CONCRETE MASONRY	G.F.B.	GROUND FACE BRICK		FOOT
	UNIT	GYP. BD.		PREFIN.	PREFINISHED
ID	CONDENSATION	H.D.	HAIR/HAND DRYER		. PROJECT MA
IN.	CONNECTION	HC HC	HANDICAPPED	QTY.	QUANTITY
IST.	CONSTRUCTION	HR.	HANDRAIL	Q.T.	QUARRY TILE
	CONSTRUCTION JOINT	HDWE.	HARDWARE	RAD.	RADIUS
ΙT	CONTINUOUS	H.V.A.C.	HEATING, VENTILATING,	RECEP.	RECEPTACLE
ITR.	CONTRACTOR		& AIR CONDITIONING	REF.	REFERENCE
R'D	CORRUGATED	HT.	HEIGHT	R.A.	RETURN AIR
R.	CORRIDOR	H.C.	HOLLOW CORE	R.H.	RIGHT HAND
R.	COUNTER	H.M.	HOLLOW METAL	R.	RISERS
	CRUSHED ROCK	HORIZ.	HORIZONTAL	R.D.	ROOF DRAIN
M.	CUBIC FEET PER	INC.	INCORPORATED	R.B.	RUBBER BASI
VI.	MINUTE	INSUL.	INSULATION	R.C.B.	RUBBER COV
Ю	DEMOLITION	INSUL.G.	INSULATED GLASS	REQD.	REQUIRED
	DETAIL	JAN.	JANITOR	R.O.W.	RIGHT OF WA
	DIAMETER	JT.	JOINT	RM.	ROOM
	DIMENSION	J.F.	JOINT FILLER	R.I.	ROUGH IN
) <u>.</u>	DISPENSER	JST.	JOIST	R.O.	ROUGH OPEN
		J.B.	JUNCTION BOX	R.S.T.	RUBBER STAI
	DIVISION	LAM.	LAMINATE	R.S.I.	RUBBER TILE
	DOOR	LAV.	LAVATORY	SAN.	SANITARY (SE
	DOUBLE	L.H.	LEFT HAND		•
	DOWNSPOUT	LG.	LONG	SCHED.	SCHEDULE
			LUINU	i	







KEYED DRAWING NOTES

- 1 EXISTING ELEVATOR CAB TO BE RENOVATED, SEE SPEC. 14210
- 2 NEW ELEVATOR CONTROLS, SEE SPEC. 14210
- 3 NEW CAR POSITION INDICATOR ABOVE ELEVATOR DOOR AT ALL FLOORS, SEE SPEC. 14210
- 4 EXISTING ELEVATOR DOORS TO REMAIN BASE BID "B" CONTRACTOR TO SAND AND REPAINT, COLOR TO MATCH EXISTING
- 5 EXISTING ELEVATOR DOOR FRAMES TO BE REPAINTED, MATCH EXISTING FINISH, VERIFY AT PROJECT SITE BASE BID "B" PROTECT ADJACENT FINISHES FROM DAMAGE DURING CONSTRUCTION
- BASE BID "B" CONTRACTOR PROVIDE AND INSTALL NEW LIBERTY ELV250 OR EQUAL SUMP PUMP SYSTEM WITH OIL DETECTION IN NEW SUMP PIT AS SHOWN. EXTEND DISCHARGE THRU SOUTH WALL AND DISCHARGE INDIRECTLY INTO EXISTING SEWAGE ENECTOR. PROVIDE AND INSTALL REMOTE ALARM ON WALL NEAR SEWAGE EJECTOR (COORDINATE LOCATION AND EXTEND CONTROL WIRING AS REQUIRED) AND PLUG INTO EXISTING NEARBY RECEPTACLE.
- 7 EXISTING ELEVATOR CAB TO REMAIN
- 8 EXISTING WALL MOUNTED SIGNAGE TO REMAIN
- 9 EXISTING FIRE ALARM SYSTEM TO REMAIN
- 10 EXISTING STEEL SUPPORT FRAMING IN ELEVATOR PIT TO REMAIN
- 11 EXISTING ELECTRICAL SWITCHES IN ELEVATOR PIT TO REMAIN
- 12 EXISTING ELECTRICAL AND TELEPHONE WIRES IN ELEVATOR PIT TO BE REMOVED OR ENCAPSULATED IN SHEET METAL ENCLOSURE, COORDINATE WITH OWNER BASE BID "B"
- BASE BID "B" CONTRACTOR EXTEND CONDUIT AND CIRCUIT FROM EXISTING NEARBY PANELBOARD OVER TO NEAR NEW SUMP PUMP. INSTALL SINGLE RECEPTACLE FOR SUMP PUMP AND NEW GFCI CONVENIENCE RECEPTACLE DOWNSTREAM OF SUMP PUMP RECEPTACLE.
- 14 INSTALL DOOR SENSOR AND INTERCONNECT WITH ELEVATOR OPERATION BASE BID "A"
- 15 INSTALL INDICATOR LIGHT ABOVE DOOR AND WIRE WITH ELEVATOR CONTROLS TO INDICATE IF ELEVATOR IS IN OPERATION BASE BID "A"
- BASE BID "B" CONTRACTOR TO INSTALL NEW 1-HOUR RATED PARTITION TO ENCAPSULATE EXISTING PIPING (2) LAYERS 5/8" GYP. WALLBOARD ATOP 3 5/8" METAL STUDS @ 16" O.C.
- REMOVE EXISTING LIGHT FIXTURE ABOVE DOOR, INSTALL NEW LED LIGHT FIXTURE EQUAL TO: LITHONIA CLX-L48-4000LM-SEF-RDL-120-40K-80CRI-WH U BASE BID "B".

8'-0" A.F.F., EXTEND EXISTING ELECTRICAL CIRCUITS IN CONDUIT AS REQUIRED - BASE BID "B".

18 INSTALL NEW LED LIGHT FIXTURE EQUAL TO: LITHONIA CLX-L48-4000LM-SEF-RDL-120-40K-80CRI-WH U, MOUNT ON WALL AT

GENERAL NOTES

- 1. CONTRACTOR SHALL VERIFY ALL DIMENSIONS AND EXISTING CONDITIONS.
- 2. COORDINATE ALL WORK WITH ALL TRADES, INCLUDING MECHANICAL, PLUMBING AND ELECTRICAL.
- 3. ALL DEMOLITION SALVAGE SHALL BE THE PROPERTY OF THE OWNER. OWNER'S REPRESENTATIVE SHALL DECIDE WHETHER TO RETAIN OR HAVE THE DEMOLITION CONTRACTOR HAUL AWAY.
- 4. AFTER DEMOLITION, THE CONTRACTOR SHALL CLEAN AREA FOR INSTALLATION OF NEW MATERIAL.
- 5. ARCHITECHNICS SHALL NOT BE RESPONSIBLE FOR NOR HAVE CONTROL OR CHARGE OF CONSTRUCTION MEANS, METHODS, TECHNIQUES, SEQUENCES OR PROCEDURES FOR THE SAFETY PRECAUTIONS AND PROGRAMS IN CONNECTION WITH THIS PROJECT, AND SHALL NOT BE RESPONSIBLE FOR CONTRACTOR'S FAILURE TO CARRY OUT HIS WORK IN ACCORDANCE WITH THE CONTRACT DOCUMENTS.
- 6. ARCHITECHNICS SHALL NOT BE RESPONSIBLE FOR, NOR HAVE CONTROL OVER, THE ACTS OR OMISSIONS OF THE CONTRACTOR, SUBCONTRACTORS, ANY OF THEIR AGENTS, OR EMPLOYEES, OR ANY OTHER PERSONS PERFORMING ANY OF THE WORK, OR FOR THE FAILURE OF ANY OF THEM TO CARRY OUT THE WORK IN ACCORDANCE WITH THE CONTRACT DOCUMENTS.
- 7. THE CONTRACTOR SHALL PROVIDE AND BE RESPONSIBLE FOR ALL TEMPORARY SHORING AND BRACING REQUIRED FOR THE CONSTRUCTION OF THIS PROJECT. ALL SHORING AND BRACING MEMBERS AND CONNECTIONS SHALL BE OF SUFFICIENT STRENGTH TO SUPPORT THE IMPOSED LOADS. TEMPORARY MEMBERS AND CONNECTIONS SHALL NOT BE REMOVED UNTIL PERMANENT MEMBERS ARE IN PLACE AND FINAL CONNECTIONS ARE MADE.
- 8. CONTRACTOR SHALL VERIFY IN FIELD ALL DIMENSIONS, ELEVATIONS, AND MEMBER SIZES AS SHOWN ON THE CONTRACT DRAWINGS FOR THE EXISTING CONSTRUCTION, PRIOR TO THE DETAILING OR FABRICATION OF ANY NEW STRUCTURAL ELEMENT. CONTRACTOR SHALL DOCUMENT ANY CONSTRUCTION-RELATED DISCREPANCIES. CONTRACTOR SHALL FURNISH THE ABOVE INFORMATION IN THE FORM OF DETAILED SKETCHES TO THE ARCHITECT/STRUCTURAL ENGINEER FOR REVIEW.
- 9. ALL DETAILS, SECTIONS, AND NOTES ON THE DRAWINGS ARE INTENDED TO BE TYPICAL FOR SIMILAR SITUATIONS ELSEWHERE, UNLESS OTHERWISE NOTED.
- 10. PROTECT EXISTING CONSTRUCTION FROM DAMAGE AS REQUIRED DURING DEMOLITION AND NEW CONSTRUCTION.

Chitects • engineers • interior designative Street, Quincy, IL 62301 • 217 - 222-0554 • info@enchitechnic Design PRM NO. 184,004061

CURRENT DATE: 10/5/2020



LICENSE EXPIRES: 11/30/22

COURTHOUSE

DAMS COUNTY CC

ISSUED FOR

BIDDING


SSUE DATE: 10/5/2020
REVISIONS

FLOOR

PROJECT NUMBER: 5991

FLOOR
PLANS AND
SECTIONS

DWG. NO. **A101**







KEYED DRAWING NOTES

- 1 EXISTING STEEL ACCESS LADDER TO REMAIN
- 2 PATCH AND REPAIR EXISTING WALLS WITH IN-KIND MATERIALS AS REQUIRED TO MAINTAIN EXISTING 1-HOUR FIRE RATING UNDER BASE BID "B"
- 3 EXISTING ELEVATOR MACHINE TO BE RENOVATED / REPLACED, SEE SPEC. 14210
- 4 EXISTING ELEVATOR MACHINE TO REMAIN (N.I.C.)
- 5 COMPLETELY REMOVE EXISTING ABANDONED CONTROL CABINET
- 6 EXISTING ELEVATOR CONTROL PANEL TO BE REMOVED AND REPLACED, SEE SPEC. 14210
- 7 EXISTING ELEVATOR GOVERNOR TO BE REMOVED AND REPLACED, SEE SPEC. 14210
- 8 EXISTING ELEVATOR GOVERNOR TO REMAIN
- 9 INSTALL NEW CLOSER ON EXISTING DOOR, EQUAL TO: DORMA U1500 SERIES UNDER BASE BID "B".
- 10 REPLACE EXISTING FLUORESCENT LIGHT FIXTURE WITH NEW LED LIGHT FIXTURE EQUAL TO: LITHONIA CLX-L48-4000LM-SEF-RDL-120-40K-80CRI-WH UNDER BASE BID "B"
- 11 REPLACE EXISTING DISCONNECT WITH NEW 100A, 3 POLE, FUSED, DOUBLE THROW, SHUNT TRIP DISCONNECT AND EXTEND TO NEW ELEVATOR MOTOR/CONTROLLER INTERCONNECT WITH FIRE ALARM AND GENERATOR CIRCUITS BASE BID "B".
- 12 EXISTING DISCONNECT SWITCH TO REMAIN
- REPLACE EXISTING INCANDESCENT LIGHT FIXTURE WITH NEW LED LIGHT FIXTURE EQUAL TO: LITHONIA CLX-L48-4000LM-SEF-RDL-120-40K-80CRI-WH U BASE BID "B".
- 14 EXISTING ELEVATOR CONTROL PANEL TO REMAIN
- EXISTING ELECTRICAL RECEPTACLE TO BE REPLACED WITH NEW GFCI RECEPTACLE (2) LOCATIONS UNDER BASE BID "B".
- 16 EXISTING CABLING TO BE ENCAPSULATED IN SHEET METAL OR OTHER ENCLOSURE AS APPROVED BY ELEVATOR INSPECTOR
- 17 EXISTING OPENING IN EXTERIOR WALL TO REMAIN, INFILL OPENING WITH IN-KIND MATERIALS AS REQUIRED
- UNDER BASE BID "B" MECHANICAL CONTRACTOR PROVIDE AND INSTALL NEW LENNOX MWMA018S42P OR EQUAL MINI-SPLIT HEAT PUMP SYSTEM HIGH ON WALL WITH MLA018S4S-1P OUTDOOR UNIT ON PRE-FABRICATED COMPOSITE BASE ON ROOF BELOW. INTERCONNECT WITH OUTDOOR UNIT FOR A COMPLETE WORKING SYSTEM. EXTEND CONDENSATE PIPING THRU EXTERIOR WALL. AT CONTRACTORS OPTION OUTDOOR UNIT CAN BE INSTALLED ON EXTERIOR WALL WITH APPROVED BRACKET.
- UNDER BASE BID "B" ELECTRICAL CONTRACTOR MODIFY EXISTING NEARBY PANELBOARD/BREAKERS AS REQUIRED AND EXTEND NEW 25A, 240V, SINGLE PHASE, (2)#10, #10G, 3/4"C CIRCUIT WITH DISCONNECT FROM EXISTING EXTERIOR HVAC PANEL TO SERVE NEW OUTDOOR HEAT PUMP UNIT AND EXTEND POWER AS REQUIRED FOR INDOOR UNIT AND INTERCONNECT FOR A COMPLETE WORKING SYSTEM.
- 20 EXTEND/MODIFY EXISTING 120V CIRCUITS FROM THIS PANEL AS REQUIRED FOR NEW ELEVATOR CAB LIGHTS, ETC.
- 21 EXTEND/MODIFY EXISTING 120V CIRCUITS FROM THIS PANEL ABOVE DOOR AS REQUIRED FOR NEW ELEVATOR CONTROL BOX
- 22 EXISTING PANELBOARDS TO REMAIN
- 23 INSTALL NEW LED LIGHT FIXTURE EQUAL TO: LITHONIA CLX-L48-4000LM-SEF-RDL-120-40K-80CRI-WH U, EXTEND EXISTING ELECTRICAL CIRCUITS IN CONDUIT AS REQUIRED BASE BID "B".
- 24 REMOVE EXISTING ELECTRICAL WIRING RUNNING THROUGH WALL

ARChitects • engineers
510 Maire Street, Quinox IL 62301 • 217.

CURRENT DATE: 10/5/2020



LICENSE EXPIRES: 11/30/22

COURTHOUSE

ADAMS COUNTY
521 VERMONT STREET, QUINCY, IL

ISSUED FOR BIDDING

SSUE DATE: 10/5/2020
REVISIONS

PROJECT NUMBER: 5991

MACHINE ROOM FLOOR PLAN AND DETAILS

DWG. NO. **A102**

© ARCHITECHNICS INC.