

## ADDENDUM

Client: Western CUSD #12

Project Name: Health Life Safety Work: Roof Replacement at: Barry and Kinderhook Schools

Project Number: 5769

Addendum Number: 2

Issued: 03/15/2019

---

This addendum becomes a part of the bidding and contract documents and modifies the drawings and specifications dated February 15, 2019. Acknowledge receipt of this addendum by noting such on the Contractor's Proposal (Bid) Form.

### FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION

This addendum and all future addenda with a Plan Holders List will be also be posted on the website of Architechnics and updated daily. Check the Current Projects tab on the site: [www.architechnicsinc.com](http://www.architechnicsinc.com)

ITEM	DESCRIPTION	NOTES
<b>SPECIFICATIONS:</b>		
Section 07 5420	Revise	Part 1.11(C)(2) - Delete this line from this section.
<b>DRAWINGS:</b>		
A1.0, A2.0	Revise:	Delete vapor barrier from new roof system where existing roof construction above deck is to remain in place.

This addendum consists of 1 page.