

## ADDENDUM

Client: Quincy Public Schools District #172

Project Name: Health Life Safety Work: Exterior Improvements at: Quincy Junior High School

Project Number: 5777

Addendum Number: 2

Issued: 04/16/2019

---

This addendum becomes a part of the bidding and contract documents and modifies the drawings and specifications dated March 28, 2019. Acknowledge receipt of this addendum by noting such on the Contractor's Proposal (Bid) Form.

### FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION

This addendum and all future addenda with a Plan Holders List will be also be posted on the website of Architechnics and updated daily. Check the Current Projects tab on the site: [www.architechnicsinc.com](http://www.architechnicsinc.com)

ITEM	DESCRIPTION	NOTES
<b>SPECIFICATIONS:</b>		
Section 04 0120.64 Section 04 0140.62	Clarify	All sealants used in repointing shall be silicone based, not urethane.
Section 00 4200	Clarify	<p>In each Base Bid Category covering brick repair and repointing, the Contractor's bid shall include the following:</p> <ol style="list-style-type: none"><li>1. An allowance to remove and replace damaged brick areas greater than groups of 7 brick, up to 300 S.F. total for the project.</li><li>2. An allowance to remove and replace damaged brick areas less than groups of 7 brick, up to 500 total units for the project.</li></ol> <p>The Contractor shall pro-rate these allowances among the various Base Bid categories of brick repair and repointing.</p>

This addendum consists of 1 page.