

## ADDENDUM

Client: Quincy Public Schools District #172

Project Name: Health Life Safety Work: Piping Replacement at: Quincy Junior High School

Project Number: 5880

Addendum Number: 1

Issued: 4/9/2020

---

This addendum becomes a part of the bidding and contract documents and modifies the drawings and specifications dated March 20, 2020. Acknowledge receipt of this addendum by noting such on the Contractor's Proposal (Bid) Form.

### FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION

This addendum and all future addenda with a Plan Holders List will be also be posted on the website of Architechnics and updated daily. Check the Contractors link on the site: [www.architechnicsinc.com](http://www.architechnicsinc.com)

ITEM	DESCRIPTION	NOTES
<b>DRAWINGS:</b>		
P001	Add	At contractor option, connect to existing 3", 2lb gas piping near new water heater location and extend new piping, regulator, and regulator to serve new water heaters.
P001	Add	Install emergency stop button/switch on wall at East corridor for water heater shutdown.
P101	Add	At contractor option Alternate Bid "A-1" water service can be installed in open trench.
P101	Add	Girl's Restroom 128 - Pipe chase shall extend up 6'-0" high. Extend vent piping from WF-1 up exposed out of top of chase and over to Room 130 and connect to existing vent piping.
P101	Add	Contractor shall extend CW piping to sinks and water closet in Break Room 154 within 48 hours after piping to Room 127 to allow for (2) sets of working restrooms.
P201	Add	Noritz is an approved manufacturer for WH-1

P201	Add	Willoughby is an acceptable manufacturer for WF-1
P201	Change	Fixture SH-1 shall have thermostatic mixing valve
P201	Add	S-1 - Install new 1/4 turn isolation valves at each location.
P001, P101, P201	Add	Contractor shall install white or black rubber hose on all existing pipe hangers to eliminate contact with piping.

This addendum consists of 2 pages; current Plan Holders List; Pre-Bid Attendance Record

# RECORD OF PLANS AND SPECIFICATIONS

PAGE NO. One

NAME OF PROJECT QJHS Piping Replacement

PROJECT NO. 5880 DATE BIDS DUE Wednesday, April 15, 2020 DEPOSIT \$150.00

TIME AND PLACE OF LETTING 3:00 QPSD #172 Board of Education  
1416 Maine Street, Quincy, IL 62301

\*\*\* Indicates Potential Bidding Contractor

Pre-Bid Meeting:

CONTRACTOR NAME ADDRESS/PHONE/EMAIL	COPY NO.	DATE RECEIVED	DATE RETURNED	DEPOSIT RECEIVED	DEPOSIT RETURNED
Architect	#1				
Owner	#2				
*** Fischer Builders, Inc. 814 Ohio Quincy, IL 62301 217-222-4322 Fax 217-222-2393 ryan@fischerbuilders.com	D	3/30/2020			
Mac's Ltd. Electrical Contractor 402 Delaware Street Quincy, IL 62301 217 223-8268 Fax: 217 223-0733 macsltd@adams.net	D	3/30/2020			
Brinkman Plumbing Co. 2510 Ellington Rd. Quincy, IL 62301 217 223-1962 Fax: 217 223-1972 janderson@brinkmanplumbing.com	D	3/30/2020			
T.F. Ehrhart Co 600 York St Quincy, IL 62301 217-222-9103 Fax: 217-228-1788 randy.rosson@tfuhrhart.com	D	3/30/2020			
Twaddle Plumbing 311 Sumac St Payson, IL 62360 217-430-1881  c.twaddle@yahoo.com	D	3/30/2020			
Sparrow Plumbing 313 Delaware Quincy, IL 62301 217 223-9289 Fax: 217 223-9880 bird@adams.net	D	3/30/2020			
Dodge Data & Analytics 4300 Beltway Place, STE #180 Arlington, Texas 888-667-8198  darlene.baker-mann@construction.c	D	3/31/2020			
Victaulic          mike.piazza@victaulic.com	D	3/31/2020			

**RECORD OF PLANS AND SPECIFICATIONS**

NAME OF PROJECT

QJHS Piping Replacement

PROJECT NO. 5880 DATE BIDS DUE 4/15/20 12:00 AM DEPOSIT: \$150.00

CONTRACTOR NAME ADDRESS/PHONE/EMAIL	COPY NO.	DATE RECEIVED	DATE RETURNED	DEPOSIT RECEIVED	DEPOSIT RETURNED
Vinson & Sill, Inc PO Box 74 Lima, IL 62348 217 985-5100 Fax: 217 985-4900 vinsil@adams.net	D	3/31/2020			
Henson Robinson Co P.O. Box 13137 Springfield, IL 62791-3137 217-544-8451 Fax: 217-544-0829 sheila@henson-robinson.com	D	4/1/2020			
Construct Connect 3825 Edwards Road, STE. 800 Cincinnati, OH 45209 800-364-2059 Rachael.Willis@constructconnect.co	D	4/1/2020			
Royalty Electric 215 S 4th Quincy, IL 62301 217-222-2027 Fax 217-222-2096 royalty1@adams.net	D	4/2/2020			

5880

Piping Replacement at QJHS

4-1-20

3:00

Isaac Miller Architects 217-222-0554 imiller@architectuicsinc.com

Clint Twaddle Twaddle plumbing 217-430-1881  
C.Twaddle@yahoo.com

Dave Sparrow Sparrow plumb bird@adams.net

Chason Gashner Vinson & Sil' c.gashner@gs.com  
gs.com

Meredith Brinkman Brinkman Plumbing mbrinkman@brinkmanplumbing.com

Jim Brinkman Brinkman Plumbing jbrinkman@brinkmanplumbing.com

Rick Coover Brown Electric Rickc@brownelectric.net