

ARCHITECHNICS, INC.
510 MAINE STREET
QUINCY, ILLINOIS 62301

PROJECT NO. : 6492

ADDENDUM NO.: 2

ISSUED: 4/15/2024

Project: Sidewalk Replacement
VIT CUSD
1502 East US HWY 136
Table Grove, IL

This addendum becomes a part of the bidding and contract documents and modifies the drawings and specifications dated March 13, 2024. Acknowledge receipt of this addendum by noting such on the Contractor's Proposal (Bid) Form.

FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION

ITEM DESCRIPTION

THIS ADDENDUM DOES NOT CHANGE THE BID DATE.

Drawings

1.0	C101 Site Plan	Clarify	Notes #1 and #8 are not used. All downspout boots and piping shown on the plans is new piping. Piping can be Dual Wall HDPE, SDR36, Or PVC.
-----	-------------------	---------	---

This addendum consists of one page.